

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6 DFS/MS/School/2020/SZ /176

Dated: 30/4/2020

FIRE SAFETY CERTIFICATE

Certified that Ratan Jee Modern School located at Tanki Road, Shakti Vihar, Badarpur, New Delhi comprised of ground plus four upper floors was granted fire safety certificate by this department vide letter No. F.6/DFS/MS/School/2016/SZ/532 dated 06/04/2016. The school building was re-inspected by officer concerned of this department on 16/04/2019 in presence of Mr. Lucky Chaudhary of the school and found that the school management have complied with the fire prevention and fire safety arrangement in accordance with Delhi Fire Service Rules, 2010 and that the school building premises is fit for occupancy class "Educational Building" Group-B" as above with effect from 30/4/2020 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/4/2020 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, Ratan Jee Modern School, Tanki Road, Shakti Vihar, Badarpur, New Delhi.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The Certificate Cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."